



PROFTECH
SPÓŁKA Z O.O.



AB 994

Research laboratory
accredited by PCA,
Nr AB 994

Scopes of accreditation:

- concentration and mass measurements of flow of fine particles
- measurements of concentration and mass flow of SO₂, NO_x, CO
- concentration measurements of CO₂, O₂
- concentration and mass flow measurements of OWO
- sampling for mass concentration determination of PCDD/PDF and dioxin type PCB
- sampling for concentration determination of (As; Cd; Cr; Co; Cu; Mn; Ni; Pb; Sb; Tl; V)
- sampling for concentration determination of Hg
- sampling and determination of concentration and mass flow of HCl
- sampling and determination of concentration and mass flow of HF
- sampling for determining the concentration of individual gaseous organic compounds
- calibration of Automated Monitoring systems,
- QAL2 procedure
- annual performance test of Automated Monitoring Systems, AST procedure
- noise measurement from machinery, installations and industrial plants

Chorzów, July 25th 2023
Our ref. No.: PW/53/07/23

Report No PW/53/07/23

on concentration measurements of dioxins, furans, heavy metals (As; Cd; Cr; Co; Cu; Mn; Ni; Pb; Sb; Tl; V and Hg) emitted into environment from stationary emission source No. 001 (waste incineration boiler stack), located at UAB Vilniaus Kogeneracinė Jėgainė, Jočionių g. 13, 02300 Vilnius

Client name and address:

UAB Vilniaus Kogeneracinė Jėgainė
Žvejų St. 14,
LT-09310 Vilnius

Developed by:

mgr Grzegorz Bortel

Calculation and data transfer checked by:

inż. Dariusz Guja

Verified by:

Company manager - inż. Dariusz Guja

Copy number: 1/3.....

inż. Dariusz Guja

ul. Kurta Aldera 44
41-506 Chorzów
tel/fax: 0 32 247 37 24

www.proftech.com.pl
e-mail: proftech@proftech.com.pl

NIP: 627 252 46 31
KRS: 0000773369

bank account : PKO BANK POLSKI S.A. O/Katowice : IBAN PL62 1440 1172 0000 0000 0353 4332

Test Report No PW/53/07/23

List of contents:

- 1. PURPOSE AND SCOPE OF THE REPORT**
- 2. BASIS OF MEASUREMENTS EXECUTION**
- 3. MEASUREMENT TEAM**
- 4. MEASUREMENT RESULTS SUMMARY**
- 5. DESCRIPTION OF THE MEASUREMENT METHOD**
- 6. MEASUREMENT RESULTS**
- 7. MEASUREMENT DEVICES**
- 8. CERTIFICATE OF ACCREDITATION**
- 9. DIOXINS AND FURANS ANALYSIS RESULTS**
- 10. MEASUREMENT PLANE SCHEME**

Test Report No PW/53/07/23

1. PURPOSE AND SCOPE OF THE REPORT

Purpose of executed measurements was to determine the concentration of dioxins, furans, heavy metals (As; Cd; Cr; Co; Cu; Mn; Ni; Pb; Sb; Tl; V and Hg) emitted to environment from stationary emission source No. 001 (waste incineration boiler stack), located at UAB Vilniaus Kogeneracinė Jėgainė, Jočionių g. 13, 02300 Vilnius

Measurements range:

- PCDD/DF concentration,
- Heavy metals (As; Cd; Cr; Co; Cu; Mn; Ni; Pb; Sb; Tl; V and Hg) concentration,

The measurements were carried out in accordance with the sampling plan and the described sampling methods.

Operating parameters of the technological installation was obtained from the customer's representative.

2. BASIS OF MEASUREMENTS EXECUTION

The measurements were taken according to the contract No VKJ_S_2020-263 dated December 16th 2020.

3. MEASUREMENT TEAM

The measurements taken on June 27th 2023 were executed by the following team:

- Grzegorz Bortel specialist - measurement team leader,
- Bartłomiej Glik specialist,

Test Report No PW/53/07/23**4. MEASUREMENT RESULTS SUMMARY**

Below are presented measurement results summary, full measurement results are presented in chapter No 6, at page 9, 12 and 13.

Stationary emission source No. 001 (waste incineration boiler stack)	Concentration of the substance in the gas in the reference conditions O2 ref. 11%	PCDDF*	ng/m3 ref.	0,0026
	Emission limits	PCDDF	ng/m3 ref.	0,10
	Transgerssion	PCDDF	ng/m3 ref.	-
	Concentration of the substance in the gas in the reference conditions O2 ref. 11%	Cd*+Tl*	mg/m3 ref.	0,005
		Hg*	mg/m3 ref.	0,000408
		Sb*+As*+Cr*+Co*+Mn*+Cu*+Ni*+Pb*+V*	mg/m3 ref.	0,024
	Emission limits	Cd+Tl	mg/m3 ref.	0,05
		Hg	mg/m3 ref.	0,05
		Sb+As+Cr+Co+Mn+Cu+Ni+Pb+V	mg/m3 ref.	0,50
	Transgerssion	Cd+Tl	mg/m3 ref.	-
		Hg	mg/m3 ref.	-
Sb+As+Cr+Co+Mn+Cu+Ni+Pb+V		mg/m3 ref.	-	

*- the results obtained from the subcontractor (accredited)

Test Report No PW/53/07/23

5. DESCRIPTION OF THE MEASUREMENT METHOD**Measurement of the gas volumetric flow**

The flow rate and density of flue gases were determined according to Polish Standard PN-Z-04030-7:1994 „Testing of particulate content. The gravimetric method measurement of concentration and particulate mass flow in flue gases" Gravimetric dust monitor type MEGASYSTEM X-1 APIS and type "S" Pitot tube were used for the measurements. Measurement is accredited.

Accreditation range: differential pressure: > 10 Pa

Measurement O₂ content

The concentration of O₂ was determined using gas analyzers HORIBA PG-350E-HR and HORIBA PG-350E-EU equipped with testing probes 1750 mm long. The measurements were taken according to the procedure described in measurement unit as well as to EN Standard PN-EN 14789:2017 "Stationary source emissions - Determination of volume concentration of oxygen O₂ - Reference method - Paramagnetism". Measurement is accredited.

Accreditation range: O₂ content: 3-21%

Measurement CO₂ content

The concentration of CO₂ was determined using gas analyzers HORIBA PG-350E-HR and HORIBA PG-350E-EU equipped with testing probes 1750 mm long. The measurements were taken according to the procedure described in measurement unit as well as to ISO Standard PN-ISO 10396:2001 "Stationary Source Emissions - Sampling For The Automated Determination Of Gas Concentrations ". Measurement is accredited.

Accreditation range: CO₂ content: 0,1-20%

Measurement of heavy metals content

Sampling for the determination of concentrations and emissions of heavy metals (Cd, Tl, Sb , As, Cr, Co, Cu , Mn , Ni , Pb, V) was performed according to PN -EN 14385 : 2005. Analysis of metals (Cd , Tl , Sb , As, Cr, Co, Cu , Mn , Ni , Pb, V) was performed in the laboratory of ŚCOP Sp. z o.o. in Czeladź , accredited in this regard by the Polish Centre of Accreditation No. AB 719

Test Report No PW/53/07/23

Measurement of mercury (Hg) content

Sampling for the determination of concentrations and emissions of mercury (Hg) was made according to PN -EN 13211 + AC : 2006. Analysis of mercury (Hg) was made in a laboratory Eurofins ŚCOP Sp. z o.o. in Czeladź , accredited in this regard by the Polish Centre of Accreditation No. AB 719

PCDD+PCDF sampling and determination

PCDD/DF samples were taken according to the requirements of Polish Standard PN-EN 1948-1:2006 „ Stationary source emissions - Determination of mass concentration of PCDDs/PCDFs and dioxin-type PCBs - Part 1: Sampling of PCDDs/PCDFs”.

The three stages of PCDD/DF concentration and emission determination:

Stage I - sampling

For the determination of mass concentration of PCDD/DF proper sampling plays important role that affects following stages of the testing. The sampling were performed by means of the filtration and condensation method using PCDD/DF sampling conformed to European Standard PN-EN 1948-1:2006.

The following page shows the schematic diagram of the sampling system.

Stage II - laboratory analysis


The samples were analysed at the ALS Czech Republic, s.r.o accredited laboratory following the CSN EN 1948-2,3 methodology: The determination of polychlorinated dibenzo-p-dioxine, dibenzofurans in emission samples with the method of isotop dillution using HRGC/HRMS.

The dioxin and furans analyses were conducted at the ALS Czech Republic, s.r.o. Laboratory, specifically accredited for the test by the Český Institut Pro Akreditaci, o.p.s. , No L1163.

Stage III - development and the results and discussion

The last stage includes results collection from the previous stages, emission calculation and PCDD/DF concentration as well as comparison to the standards in force.

Test Report No PW/53/07/23



- Opis:
- 1. ferrule
 - 2. cooler
 - 5,10. aspiration path - tubes
 - 13. clamp
 - 20. Pitot tube „S” - type
 - 25. cooler casing
 - 3. condensation pot
 - 6-8. scrubbers
 - 16. holding springs
 - 21. filter casing
 - 26. heated probe
 - 4,18. aspiration path - elbows
 - 9. aspiration path - probe tube
 - 17. aspiration controller
 - 22. yoke
 - 28. cooler coil
 - 11,12,14,15. - aspiration endings
 - 19. temperature controller
 - 24. gas dryer
 - 29,30. support

Test Report No PW/53/07/23

6. MEASUREMENT RESULTS

Test Report No PW/53/07/23

- 1) Plant or unit name¹⁾: **Stationary emission source No. 001 (waste incineration boiler stack)**
- 2) Flue gases cleaning unit¹⁾: **Evaporative cooler, hydrated lime and active carbon reactor, bag filters unit (2x4)**
- 3) Emission source load during measurements¹⁾: **Boiler load ~67,8 MW,**
- 4) Fuel type or material mass flow in process¹⁾: **Waste ~18,8 t/h**
- 5) Location of sampling and measurements: **in duct, after flue gases cleaning unit**

Measurement reference number		27-06-01		X	X		
Date of measurement		27.06.2023					
Measurement time range		13:00-19:00					
Scope of test		Unit	Results	Uncertainty +/-	Method		
Meteorological conditions	Atmospheric pressure	hPa	988,5	X	PN-Z-04030-7:1994		
	Ambient temperature	oC	25				
Measurement plane	Diameter	m	2,10				
	Area	m2	3,4619				
The parameters of gas in line	Temperature	oC	37				
	Static pressure	Pa	-75				
	Differential pressure	Pa	110				
	Gas moistness grade X	kg/kg	0,070			PN-EN 14790:2017	
	Average velocity	m/s	10,7			0,1	PN-Z-04030-7:1994
	Chemical composition	O2	%			7,0	0,2
		CO2	%	12,1	0,5	PN-ISO 10396:2001	
	Wet gas density during testing	kg/m3	1,109	X	PN-EN 14790:2017		
	Gas density in normal conditions	kg/m3 N	1,292		PN-EN 14790:2017		
	Gas density in conventional conditions	kg/m3 U	1,349		PN-EN 14790:2017		
Concentration of the substance in the gas in reference conditions O2 ref. 11%	PCDDF*	ng/m3 ref.	0,0026	0,0008	PN-EN 1948:2006		
Gas volume flow	measurement conditions	m3/h	133352	2235	PN-Z-04030-7:1994		
	normal conditions	m3N/h	114511	1997			
	standard conditions	m3U/h	102459	4377			
	reference conditions O2 ref. 11%	m3ref./h	143443	6668			
Emission limits	PCDDF*	ng/m3 U	0,10	X	X		
Transgerssion	PCDDF*	ng/m3 U	-				

*- the results obtained from the subcontractor (accredited)

¹⁾-information obtained from the client

Test Report No PW/53/07/23**Notes:**

Normal conditions designate the temperature of 273 K and pressure of 101,3kPa, defining normal cubic meter m³N. The standard conditions designate the temperature of 273K, pressure of 101,3 kPa and dry gases (steam contents less than 5 g/kg of flue gas), defining standard cubic meter, m³U

The specified expanded uncertainty comes from standard uncertainty multiplied by expansion coefficient k = 2, which provides 95% level of confidence for normal distribution. Uncertainty takes into account the sampling and analysis.

Registry of samples delivered to the laboratory: P/01/07/23, P/02/07/23

Date of delivery to the laboratory: 04.07.2023

Date of analysis: 04.07.2023 - 24.07.2023

Field blanks:

ID/ number of sample	Type of substance	The criterion of the blank [ng/m ³] 11%O ₂	The value of the blank [ng/m ³] 11% O ₂	Result [+/-]
P/02/07/23	PCDD/DF	0,01	0,0021	+

PCDD/DF (PN-EN 1948:2006):

sampling method: condensation - adsorption method

filter parameters: 19 x 90 mm, filter efficiency: 99,998 %

sampling plane: 2 measurement axis

oxygen reference : 11 %

time of dioxins and furans measurement: 13:00 – 19:00 (360 min)

nozzle diameter: 6 mm

probe temperature: 121 °C

scrubbers temperature 6 °C

aspired gas volume 5,54 m³

average sampling flow 15,4 l/min

izokinetic ratio: 96,5 %

leak test: + / +

gas meter temperature 29 °C

gas meter pressure 0 bar

spiking pattern: filter surface

absorption solution: 100 ml H₂O dest. + 50 ml 2-etoksyetanol

recovery: 95 % ¹³C₁₂-2,3,4,7,8-PECDF, />50%/

93 % ¹³C₁₂-1,2,3,6,7,8-HxCDF, />50%/

54 % ¹³C₁₂-1,2,3,4,6,7,8 HpCDF. />50%/

TEQ sample mass: 0,018 ng

Test Report No PW/53/07/23

- 1) Plant or unit name¹⁾: **Stationary emission source No. 001 (waste incineration boiler stack)**
- 2) Flue gases cleaning unit¹⁾: **Evaporative cooler, hydrated lime and active carbon reactor, bag filters unit (2x4)**
- 3) Emission source load during measurements¹⁾: **Boiler load ~67,8 MW,**
- 4) Fuel type or material mass flow in process¹⁾: **Waste ~18,8 t/h**
- 5) Location of sampling and measurements: **in duct, after flue gases cleaning unit**

Measurement reference number			27-06-01		X	X	X	
Date of measurement			27.06.2023					
Measurement time range			13:25-14:26	14:31-15:32				
Scope of test		Unit	Results		Average	Uncertainty +/-	Method	
Meteorological conditions	Atmospheric pressure	hPa	990,2	989,8	990,0		PN-Z-04030-7:1994	
	Air temperature	oC	25	25	25			
Measurement plane	Diameter	m	2,10					
	Area	m2	3,4619					
Stack gas parameters	Temperature	oC	40,5	39,7	40,1			
	Static pressure	Pa	-39,2	-36,6	-37,9			
	Dynamic pressure	Pa	91,5	89,4	90,5			
	Gas moistness grade X	kg/kg	0,066	0,074	0,070			PN-EN 14790:2017
	Average velocity	m/s	10,2	10,1	10,1	0,2		PN-Z-04030-7:1994
	Chemical composition	O2	%	6,60	7,20	6,90		0,18
		CO2	%	12,60	12,00	12,30	0,47	PN-ISO 10396:2001
	Wet gas density during testing	kg/m3	1,104	1,099	1,101		PN-Z-04030-7:1994	
	Gas density in normal conditions	kg/m3 N	1,297	1,289	1,293		PN-Z-04030-7:1994	
	Gas density in standard conditions	kg/m3 U	1,352	1,349	1,350		PN-Z-04030-7:1994	
Concentration of the substance in the gas in reference conditions O2 ref. 11%	As gaseus*	mg/m ³ _{ref}	< 0,003294	< 0,003887	< 0,003591	0,000760	PN-EN 14385:2005	
	As dust*	mg/m ³ _{ref}	< 0,000424	< 0,000468	< 0,000446	0,000095	PN-EN 14385:2005	
	As*	mg/m ³ _{ref}	< 0,003718	< 0,004355	< 0,004037	0,000766	PN-EN 14385:2005	
	Sb gaseus*	mg/m ³ _{ref}	< 0,003294	< 0,003887	< 0,003591	0,000760	PN-EN 14385:2005	
	Sb dust*	mg/m ³ _{ref}	< 0,000424	< 0,000468	< 0,000446	0,000095	PN-EN 14385:2005	
	Sb*	mg/m ³ _{ref}	< 0,003718	< 0,004355	< 0,004037	0,000766	PN-EN 14385:2005	
	Cd gaseus*	mg/m ³ _{ref}	< 0,000659	< 0,000777	< 0,000718	0,000087	PN-EN 14385:2005	
	Cd dust*	mg/m ³ _{ref}	< 0,000085	< 0,000094	< 0,000090	0,000011	PN-EN 14385:2005	
	Cd*	mg/m ³ _{ref}	< 0,000744	< 0,000871	< 0,000808	0,000088	PN-EN 14385:2005	
	Co gaseus*	mg/m ³ _{ref}	< 0,001647	< 0,001944	< 0,001796	0,000219	PN-EN 14385:2005	
	Co dust*	mg/m ³ _{ref}	< 0,000212	< 0,000234	< 0,000223	0,000028	PN-EN 14385:2005	
	Co*	mg/m ³ _{ref}	< 0,001859	< 0,002178	< 0,002019	0,000221	PN-EN 14385:2005	
	Mn gaseus*	mg/m ³ _{ref}	< 0,000329	< 0,000389	< 0,000359	0,000146	PN-EN 14385:2005	
	Mn dust*	mg/m ³ _{ref}	< 0,000042	< 0,000047	< 0,000045	0,000006	PN-EN 14385:2005	
	Mn*	mg/m ³ _{ref}	< 0,000371	< 0,000436	< 0,000404	0,000146	PN-EN 14385:2005	
	Cu gaseus*	mg/m ³ _{ref}	< 0,001647	< 0,001944	< 0,001796	0,000249	PN-EN 14385:2005	
	Cu dust*	mg/m ³ _{ref}	0,000538	0,000473	0,000506	0,000067	PN-EN 14385:2005	
	Cu*	mg/m ³ _{ref}	0,002185	0,002417	0,002301	0,000258	PN-EN 14385:2005	
	Ni gaseus*	mg/m ³ _{ref}	< 0,001647	< 0,001944	< 0,001796	0,000249	PN-EN 14385:2005	
	Ni dust*	mg/m ³ _{ref}	< 0,000212	< 0,000234	< 0,000223	0,000031	PN-EN 14385:2005	
	Ni*	mg/m ³ _{ref}	< 0,001859	< 0,002178	< 0,002019	0,000251	PN-EN 14385:2005	
	Pb gaseus*	mg/m ³ _{ref}	< 0,001647	< 0,001944	< 0,001796	0,000414	PN-EN 14385:2005	
	Pb dust*	mg/m ³ _{ref}	0,000419	0,000552	0,000486	0,000115	PN-EN 14385:2005	
	Pb*	mg/m ³ _{ref}	0,002066	0,002496	0,002281	0,000430	PN-EN 14385:2005	

Test Report No PW/53/07/23

	V gaseus*	mg/m ³ _{ref}	< 0,003294	< 0,003887	< 0,003591	0,000760	PN-EN 14385:2005
	V dust*	mg/m ³ _{ref}	< 0,000424	< 0,000468	< 0,000446	0,000095	PN-EN 14385:2005
	V*	mg/m ³ _{ref}	< 0,003718	< 0,004355	< 0,004037	0,000766	PN-EN 14385:2005
	Cr gaseus*	mg/m ³ _{ref}	< 0,002635	< 0,003110	< 0,002873	0,000575	PN-EN 14385:2005
	Cr dust*	mg/m ³ _{ref}	< 0,000339	< 0,000374	< 0,000357	0,000072	PN-EN 14385:2005
	Cr*	mg/m ³ _{ref}	< 0,002974	< 0,003484	< 0,003229	0,000579	PN-EN 14385:2005
	Tl gaseus*	mg/m ³ _{ref}	< 0,003294	< 0,003887	< 0,003591	0,001106	PN-EN 14385:2005
	Tl dust*	mg/m ³ _{ref}	< 0,000424	< 0,000468	< 0,000446	0,000138	PN-EN 14385:2005
	Tl*	mg/m ³ _{ref}	< 0,003718	< 0,004355	< 0,004037	0,001115	PN-EN 14385:2005
Gas volume flow	measurement conditions	m ³ /h	126747	125625	126186	2115	PN-Z-04030-7:1994
	normal conditions	m ³ _n /h	107846	107125	107485	1874	
	standard conditions	m ³ _s /h	97014	95338	96176	4109	
	reference conditions O2 ref. 11%	m ³ _{ref} /h	139701	131566	135634	6305	
Emission limits	Cd*+Tl*	mg/m ³ _{ref}	0,05				
	Sb*+As*+Cr*+Co*+Mn*+Cu*+Ni*+Pb*+V*	mg/m ³ _{ref}	0,50				
Concentration of the substance in the gas in reference conditions O2 ref. 11%	Cd*+Tl*	mg/m ³ _{ref}	0,005				
	Sb*+As*+Cr*+Co*+Mn*+Cu*+Ni*+Pb*+V*	mg/m ³ _{ref}	0,024				

* - the results obtained from the subcontractor (accredited)

¹⁾-information obtained from the clientNotes:

Normal conditions designate the temperature of 273 K and pressure of 101,3kPa, defining normal cubic meter m³N. The standard conditions designate the temperature of 273K, pressure of 101,3 kPa and dry gases (steam contents less than 5 g/kg of flue gas), defining standard cubic meter, m³U

The specified expanded uncertainty comes from standard uncertainty multiplied by expansion coefficient k = 2, which provides 95% level of confidence for normal distribution. Uncertainty takes into account the sampling and analysis.

Registry of samples delivered to the laboratory: P/03/07/23, P/04/07/23, P/05/07/23, P/06/07/23, P/07/07/23, P/08/07/23, P/09/07/23,

Date of delivery to the laboratory: 04.07.2023

Date of analysis: 04.07.2023 - 14.07.2023

Field blanks:

ID/ number of sample	Type of substance	The criterion of the blank [mg/m ³] 11%O ₂	The value of the blank [mg/m ³] 11% O ₂	Result [+/-]
P/07/07/23	Cd+Tl	0,005	p.o.	+
P/07/07/23	Sb+As+Pb+Cr+Co+Cu+Mn+Ni+V	0,05	p.o.	+

p.o. – below the limit of quantification.

Test Report No PW/53/07/23

- 1) Plant or unit name¹⁾: **Stationary emission source No. 001 (waste incineration boiler stack)**
 2) Flue gases cleaning unit¹⁾: **Evaporative cooler, hydrated lime and active carbon reactor, bag filters unit (2x4)**
 3) Emission source load during measurements¹⁾: **Boiler load ~67,8 MW,**
 4) Fuel type or material mass flow in process¹⁾: **Waste ~18,8 t/h**
 5) Location of sampling and measurements: **in duct, after flue gases cleaning unit**

Measurement reference number			27-06-01		X	X	X	
Date of measurement			27.06.2023					
Measurement time range			15:39-16:40	16:48-17:49				
Scope of test		Unit	Results		Average	Uncertainty +/-	Method	
Meteorological conditions	Atmospheric pressure	hPa	989,3	989,3	989,3		PN-Z-04030-7:1994	
	Air temperature	oC	24	23	24			
Measurement plane	Diameter	m	2,10					
	Area	m ²	3,4619					
Stack gas parameters	Temperature	oC	39,1	38,7	38,9			
	Static pressure	Pa	-39,9	-50,3	-45,1			
	Dynamic pressure	Pa	88,2	89,9	89,1			
	Gas moistness grade X	kg/kg	0,075	0,071	0,073			PN-EN 14790:2017
	Average velocity	m/s	10,0	10,1	10,0	0,2		PN-Z-04030-7:1994
	Chemical composition	O ₂	%	7,00	7,20	7,10		0,18
		CO ₂	%	12,10	11,80	11,95	0,46	PN-ISO 10396:2001
	Wet gas density during testing	kg/m ³	1,100	1,103	1,101		PN-Z-04030-7:1994	
	Gas density in normal conditions	kg/m ³ N	1,288	1,290	1,289		PN-Z-04030-7:1994	
Gas density in standard conditions	kg/m ³ U	1,349	1,347	1,348		PN-Z-04030-7:1994		
Concentration of the substance in the gas in reference conditions O ₂ ref. 11%	Hg gaseus*	mg/m ³ _{ref}	0,000496	0,000262	0,000379	0,000100	PN-EN 13211+AC:2006	
	Hg dust*	mg/m ³ _{ref}	0,000039	0,000019	0,000029	0,000008	PN-EN 13211+AC:2006	
	Hg*	mg/m ³ _{ref}	0,000535	0,000281	0,000408	0,000100	PN-EN 13211+AC:2006	
Gas volume flow	measurement conditions	m ³ /h	124628	125750	125189	2098	PN-Z-04030-7:1994	
	normal conditions	m ³ _n /h	106424	107509	106966	1865		
	standard conditions	m ³ _u /h	94570	96135	95352	4073		
	reference conditions O ₂ ref. 11%	m ³ _{ref} /h	132398	132666	132532	6174		
Emission limits	Hg*	mg/m ³ _{ref}	0,05					
Concentration of the substance in the gas in reference conditions O ₂ ref. 11%	Hg*	mg/m ³ _{ref}	0,000408					

*- the results obtained from the subcontractor (accredited)

¹⁾-information obtained from the client

Notes:

Normal conditions designate the temperature of 273 K and pressure of 101,3kPa, defining normal cubic meter m³N. The standard conditions designate the temperature of 273K, pressure of 101,3 kPa and dry gases (steam contents less than 5 g/kg of flue gas), defining standard cubic meter, m³U

The specified expanded uncertainty comes from standard uncertainty multiplied by expansion coefficient k = 2, which provides 95% level of confidence for normal distribution. Uncertainty takes into account the sampling and analysis.

Test Report No PW/53/07/23

Registry of samples delivered to the laboratory: P/10/07/23, P/11/07/23, P/12/07/23, P/13/07/23, P/14/07/23

Date of delivery to the laboratory: 04.07.2023

Date of analysis: 04.07.2023 - 14.07.2023

Field blanks:

ID/ number of sample	Type of substance	The criterion of the blank [mg/m ³] 11%O ₂	The value of the blank [mg/m ³] 11% O ₂	Result [+/-]
P/12/07/23	Hg	0,005	p.o.	+

p.o. – below the limit of quantification.

Work parameters of measurement system:**Heavy metals (PN-EN 14385:2005)**

Sampling plane: 2 measurement axis
 Sampling: isokinetic [x]
 nonisokinetic []
 Isokinetic ratio: 114,4 / 109,8 %
 Sampling time: 60,8 / 60,9 min
 Sampled volume: 0,157/ 0,143 m³
 Filter parameters: FT-50: Ø 0,50 mm, efficiency: 99,990 %, quartz (QMA)
 Impingers: impingers set No. 1 (absorption efficiency 98,5 %)
 Absorption solution: HNO₃/H₂O₂

Hg (PN-EN 13211 + AC:2006)

Sampling plane: 2 measurement axis
 Sampling: isokinetic [x]
 nonisokinetic []
 Isokinetic ratio: 106,3 % / 113,2 %
 Sampling time: 60,9 min / 60,8 min
 Sampled volume: 0,131 m³ / 0,169 m³
 Impingers: impingers set No. 3 (absorption efficiency 97,2 %)
 Absorption solution: No. I (manganese (VII) potassium / sulfuric acid (VI))

H₂O (PN-EN 14790:2017)

Sampling plane: 2 measurement axis
 Sampling equipment: titanium sampling line
 heated probe 2,0 m
 sampling pump: PT-01
 Cartridge No: H₂O content set No 1
 Sampling No: 1 - 4
 Sampling time: ~61 min
 Sampling speed: ~3,0 l/min
 H₂O maas: 9,5 – 12,0 g
 absorption efficiency: 98,7 %

Test Report No PW/53/07/23**7. MEASUREMENT DEVICES**

Name of measuring device		X1- Apis
Type of measuring device		Isokinetic sampler S/N 0185
Certificate	Calibration No	94/54/LA/P/2023 G-73/23-46/23 65/1/T/23
Issued by		ZAP BESTWINKA LABOSERWIS SP. Z O.O. KATOWICE PLUM SP. Z O.O. KLEOSIN
Date of issue the certificate of calibration		27.02.2023 r. 23.02.2023 r. 02.03.2023 r.
Expiration date of the certificate of calibration		-

Name of measuring device		HORIBA
Type of measuring device		PG-350E-EU
Certificate	Calibration No	130/1/AW/21
Issued by		Laboserwis Sp. z o.o. Katowice
Date of issue the certificate of calibration		28.05.2021
Expiration date of the certificate of calibration		-

Name of measuring device		Sampler
Type of measuring device		PT-01
Certificate	Calibration No	G-354/22-208/22 1189/436/LA/T/2022 786/281/LA/P/2022
Issued by		ZAP BESTWINKA PLUM SP. Z O.O. KLEOSIN
Date of issue the certificate of calibration		30.08.2022 06.09.2022 09.09.2022
Expiration date of the certificate of calibration		-

Name of measuring device		Sampler
Type of measuring device		LIFETEK 55 XP-R nr 55381 + ISOCHECK-SRB nr ISO0571
Certificate	Calibration No	174/87/LA/P/2021 02.04.2021 T146/PMT/2021 12.05.2021 G-103/21-72/21 19.03.2021
Issued by		PLUM Sp. z o.o. KLEOSIN CZAH-POMIAR Sp. z o.o. KATOWICE ZAP J.FIRGANEK BESTWINKA
Date of issue the certificate of calibration		02.04.2021 12.05.2021 19.03.2021
Expiration date of the certificate of calibration		-

Test Report No PW/53/07/23

8. CERTIFICATE OF ACCREDITATION

POLSKIE CENTRUM AKREDYTACJI
POLISH CENTRE FOR ACCREDITATIONSygnatariusz EA MLA
EA MLA SignatoryCERTYFIKAT AKREDYTACJI
LABORATORIUM BADAWCZEGO
ACCREDITATION CERTIFICATE OF TESTING LABORATORY

Nr AB 994

Potwierdza się, że: / This is to confirm that:

„PROFTECH” Sp. z o.o.
ul. Kurta Aldera 44, 41-506 Chorzówspełnia wymagania normy PN-EN ISO/IEC 17025:2018-02
meets requirements of the PN-EN ISO/IEC 17025:2018-02 standardAkredytowana działalność jest określona w Zakresie Akredytacji Nr AB 994
Accredited activity is defined in the Scope of Accreditation No AB 994Akredytacja pozostaje w mocy pod warunkiem przestrzegania
wymagań jednostki akredytującej określonych w kontrakcie Nr AB 994
This accreditation remains in force provided the Laboratory observes
the requirements of Accreditation Body defined in the Contract No AB 994Akredytacji udzielono dnia 30.01.2009 r.
Accreditation was granted on 30.01.2009DYREKTOR
POLSKIEGO CENTRUM AKREDYTACJI

LUCYNA OLBORSKA

Warszawa, dnia 8 grudnia 2019 roku

Test Report No PW/53/07/23

9. DIOXINS AND FURANS ANALYSIS RESULTS

Attachment no. 1 to the Certificate of Analysis for work order PR2375399

Sample: P/01/07/23

Measurement results PCDD/Fs:

Sample: P/01/07/23		Final extract [µl]: 60			
		Injection volume [µl]: 4			
		Acquisition date [d.m.y h:m]: 15.7.23 20:42			
2,3,7,8-PCDD/Fs	Result [ng/sample]	Limit of Detection [ng/sample]	Limit of Quantification [ng/sample]	I-TEQ ¹	I-TEQ Upperbound [ng/sample]
2,3,7,8-TCDD	< 0.0052	0.0052	0.01	1	0.0052
1,2,3,7,8-PeCDD	< 0.0059	0.0059	0.012	0.5	0.003
1,2,3,4,7,8-HxCDD	< 0.0086	0.0086	0.017	0.1	0.00086
1,2,3,6,7,8-HxCDD	< 0.0086	0.0086	0.017	0.1	0.00086
1,2,3,7,8,9-HxCDD	< 0.0086	0.0086	0.017	0.1	0.00086
1,2,3,4,6,7,8-HpCDD	< 0.0093	0.0093	0.019	0.01	0.000093
OCDD	< 0.016	0.016	0.032	0.001	0.000016
2,3,7,8-TCDF	< 0.006	0.006	0.012	0.1	0.0006
1,2,3,7,8-PeCDF	< 0.0058	0.0058	0.012	0.05	0.00029
2,3,4,7,8-PeCDF	< 0.0058	0.0058	0.012	0.5	0.0029
1,2,3,4,7,8-HxCDF	< 0.0087	0.0087	0.017	0.1	0.00087
1,2,3,6,7,8-HxCDF	< 0.0087	0.0087	0.017	0.1	0.00087
1,2,3,7,8,9-HxCDF	< 0.0087	0.0087	0.017	0.1	0.00087
2,3,4,6,7,8-HxCDF	< 0.0087	0.0087	0.017	0.1	0.00087
1,2,3,4,6,7,8-HpCDF	< 0.0098	0.0098	0.02	0.01	0.000098
1,2,3,4,7,8,9-HpCDF	< 0.0098	0.0098	0.02	0.01	0.000098
OCDF	< 0.015	0.015	0.031	0.001	0.000015
I-TEQ from quantified 2,3,7,8-PCDD/Fs - "Lowerbound"					0
I-TEQ from 2,3,7,8-PCDD/Fs - "Mediumbound"					0.0092
Maximum possible I-TEQ - "Upperbound"					0.018
PCDDs	Result [ng/sample]	PCDFs	Result [ng/sample]		
Tetra-CDDs	< 0.11	Tetra-CDFs	< 0.23		
Penta-CDDs	< 0.083	Penta-CDFs	< 0.16		
Hexa-CDDs	< 0.086	Hexa-CDFs	< 0.14		
Hepta-CDDs	< 0.019	Hepta-CDFs	< 0.039		
OCDD	< 0.016	OCDF	< 0.015		

¹I-TEQ according to NATO.

Limits of quantification are defined as double of the detection limits.

The limit of detection is defined as the amount of analyte producing a signal with S/N≥3.

The value of the detection limit is mentioned as the actual value at the acquisition date.

Measurement uncertainty is expressed as a double (k=2) relative standard deviation (RSD%), and corresponds to 95% confidence interval.

Estimation of uncertainty of each 2,3,7,8-PCDD/F congener is 30% and total I-TEQ is 20%.

These values were ensured by analyses of certified reference material under conditions of internal reproducibility.

Results marked with "<" are below limit of detection or quantification.

"Lowerbound" and "Upperbound" are levels defined in Regulation 2017/644 and EN 1941-4.

"Mediumbound" is levels defined in Regulation 2017/644.

Test Report No PW/53/07/23**Attachment no. 1 to the Certificate of Analysis for work order PR2375399**

Sample:


P/01/07/23

Standards recovery:

Sample:		P/01/07/23			
		Final extract [μl]:		60	
		Injection volume [μl]:		4	
		Acquisition date (d.m.y h:m):		15.7.23 20:42	
Extraction standard	Recovery	Acceptable range (%)		Accept. rec. with respect to	
PCDDs	(%)	Basic	Extended	basic range	extended range
13C12-2,3,7,8-TCDD	69	50 - 130	30 - 150	YES	-
13C12-1,2,3,7,8-PeCDD	95	50 - 130	30 - 150	YES	-
13C12-1,2,3,4,7,8-HxCDD	100	50 - 130	30 - 150	YES	-
13C12-1,2,3,6,7,8-HxCDD	97	50 - 130	30 - 150	YES	-
13C12-1,2,3,4,6,7,8-HpCDD	78	40 - 130	20 - 150	YES	-
13C12-OCDD	63	40 - 130	20 - 150	YES	-
PCDFs					
13C12-2,3,7,8-TCDF	59	50 - 130	30 - 150	YES	-
13C12-2,3,4,7,8-PeCDF	61	50 - 130	30 - 150	YES	-
13C12-1,2,3,4,7,8-HxCDF	110	50 - 130	30 - 150	YES	-
13C12-1,2,3,6,7,8-HxCDF	110	50 - 130	30 - 150	YES	-
13C12-2,3,4,6,7,8-HxCDF	64	50 - 130	30 - 150	YES	-
13C12-1,2,3,4,6,7,8-HpCDF	110	40 - 130	20 - 150	YES	-
13C12-OCDF	53	40 - 130	20 - 150	YES	-
Sampling standard	Recovery	Acceptable range		Rec. in range?	
	(%)	(%)			
13C12-1,2,3,7,8-PeCDF	95	> 50		YES	
13C12-1,2,3,7,8,9-HxCDF	93	> 50		YES	
13C12-1,2,3,4,7,8,9-HpCDF	54	> 50		YES	

Test Report No PW/53/07/23

10. MEASUREMENT PLANE SCHEME



Approved by

..... DYREKTOR
Name and Signature
inż. Dariusz Guja

END OF REPORT